


US EPA ARCHIVE DOCUMENT

Pathogen/biofilm studies to aid QMRA & research planning


Nicholas J. Ashbolt
Ashbolt.Nick@epa.gov

**EPA RESEARCH FORUM: Advancing Public
Health Protection through Water Infrastructure
Sustainability, Potomac Yards Arlington VA**

April 11th, 2013



QMRA – Analytic Framework




STEP 1
SETTING


Problem formulation & Hazard identification
Describe physical system, selection of **reference pathogens** and **identification of hazardous events**

Quantitative microbial risk assessment (QMRA)

STEP 2
EXPOSURE



STEP 3
HEALTH EFFECTS



STEP 4
RISK

STEP 1 SETTING


Hazard identification & characterization
Describe physical system, selection of reference pathogens and identification of hazardous events



AF-RICP issues 2010

STEP 2 EXPOSURE

For each reference pathogen:





DWDS *Norovirus* risk*

- Maintaining a free chlorine residual of 0.2 mg/L or above is the last defense against the risk of viral infection due to negative pressure transients
- Maintaining a chloramine residual did not appear to significantly reduce viral risk
- Effectiveness of ensuring separation distances from sewer mains to reduce risk may be system-specific
- Leak detection/repair and cross-connection control should be prioritized in areas vulnerable to negative pressure transients

*Yang *et al.* (2011) J Water Health 9:291–305

GI RR 1.6 if low pressure Nygård *et al* (2007) Int J Epi 36:873-880

STEP 1 SETTING

Hazard identification & characterization
Describe physical system, selection of reference
pathogens and identification of hazardous events



Public health costs from water

- CDC estimate waterborne disease costs > \$970 m/y
 - Addressing giardiasis, cryptosporidiosis, Legionnaires' disease, *otitis externa*, and non-tuberculous mycobacterial infections, causing over 40 000 hospitalizations per year

Disease	\$ / hospitalization	Total cost
Cryptosporidiosis	\$16 797	\$45 770 572
Giardiasis	\$9 607	\$34 401 449
Legionnaires' disease	\$33 366	\$433 752 020
NTM infection/Pulmonary	\$25 985 / \$25 409	\$425 788 469/ \$194 597 422


Also, nutrients & environmental pathogens even more likely intrude than enteric pathogens




- Providing continued input of environmental pathogens to storage reservoir sediments, pipe biofilms and in-premise pipe surfaces
 - i.e. for growth of NTM, legionellae, *Pseudomonas aeruginosa* etc. if other ecological conditions allow



Conceptual *Legionella* model: piped water





Legionella biofilm release scenarios

Risk size: < 7 micron aerosols


- a) *Legionella* that have proliferated within **biofilm** released as this material sloughs off ✓
- b) Within released amoebae **trophozoites** ✓
- c) Within **vesicles** excreted by amoebae or ✓
- d) Within released amoebae **cysts** ?

QMRA for critical *Legionella* densities

Critical # in DW
 $10^6 - 10^8 \text{ CFU L}^{-1}$

based on QMRA model
Needs hosts to reach that

Biofilm
colonization and
detachment



Aerosolization

Critical # $35 - 3,500 \text{ CFU m}^{-3}$
based on QMRA model



Inhalation

Deposition

**$1-1,000 \text{ CFU}$ in lung
for potential illness**

Environ Path research gaps (2010)

- Partitioning coefficients needed for a variety of environmental pathogens
- Fraction of community-acquired respiratory disease from *Legionella*, MAC/NTM?
- **Host-pathogen ecology-management in water system environments**




How many *Legionella* per amoeba?

Flow cytometer sorted (red zone) & culture to estimate *Legionella* CFU trophozoite⁻¹

- *Acanthamoeba polyphaga*
1,348 (mean, 329)
- *Naegleria fowleri* 385
(mean, 44)

Buse & Ashbolt (2012)
AEM 78(6):2070-2072






Drinking water biofilm microbiota

- Metagenomics undertaken to date shows
 - 18S rDNA (amoebae, nematodes, rotifers), e.g.
 - amoebae: ***Hartmannella vermiformis***, & species of *Echinamoeba*, *Pseudoparamoeba*, *Protacanthamoeba*, *Platyamoeba* & *Vannella*
Buse *et al.* (accepted) Env Sci Pollut Res
 - 16S rDNA (*Bacteria*) for NH₂Cl-treated water
 - After 3-4 months 'stable' community of *Actinobacteria*, *Bacteroidetes* & *Proteobacteria*, with >30% ***Mycobacterium* spp.**
Revetta *et al.* (accepted) FEMS Micro Lett

Current *Legionella* disinfection/control

- Thermal (80 °C, 10 min)
 - most effective, but only if repeated frequently (used in health care centers)
- Monochloramine (NH_2Cl) more effective than free chlorine (HOCl)
 - planktonic
 - sessile/biofilm (increased resistance)
 - amoeba-bound (further increased resistance)
- Point of use control: Filtering & Cu/Ag ions used in hospital/care facilities (impact on culturable cells)





Does aged biofilm on copper pipe suppress *Legionella* vs on PVC?

- Spiked 1 y-old PVC & Cu lab DW pipe biofilms, followed 4 mo
- *L. pneumophila* maintained cultivability in PVC biofilms compared to below detectable CFUs from Cu biofilms
- However, *L. pneumophila* cells shed in reactor effluent water reflected persistent VBNC *L. pneumophila* (more if + amoebae) within Cu-coupon vs few VBNC with PVC-coupon reactors
- Also effluent samples from inoculated Cu reactors contained more & for months longer culturable *L. pneumophila* than PVC inoculated reactors



Stress & *Legionella*'s transcriptome

- **Methods:** CuO-nanoparticle exposure as the stressor for *L. pneumophila* Philadelphia 1:
 - Using a whole genome *Legionella* microarray
 - RT-qPCR assays of expressed mRNA
- Identified expression of genes involved in metabolism, transcription, translation, replication-repair, and virulence (e.g. *ceg29* and *rtxA*)
- Now using RT-qPCR to understand biofilm & intra-amoebal stress for *Legionella* vs. various disinfectants

Lu *et al.* (2013) Appl Environ Microbiol 79: 2713-2720




***Legionella* QMRA summary**

- Wide potential dose of concern in lungs
- Air-water partitioning drives the dose
- Critical *Legionella* densities likely high
 - So sig numbers readily detectable, and
 - Low numbers in drinking water minimal direct concern, but seed downstream premise plumbing
 - Various amoebae host common, reduc. disinfection
- Potential risk not associated with fecal indicators, & NH_3Cl → increased MAC risk



Pathogen-biofilm timeline





Conclusions: QMRA gaps

- What fraction of qPCR positives are viable or infectious, by water disinfection process
- What fraction of pathogens release from filters & biofilms and under what conditions
- Need to correlate qPCR targets to actual pathogens for different environments (F & T)
- Need dose-response data for environmental pathogens and enteric viruses



Disclaimer/Acknowledgements

The views expressed in this presentation are those of the author and do not necessarily represent the views or policies of the U.S. Environmental Protection Agency

Helen Buse, Jingrang Lu, Ian Struewing,
Sébastien Faucher, Jorge Santo Domingo,
Randy Revetta, Vicenté Gomez-Alvarez,
Jacquie Thomas and Michael Storey

